



**CHINA QUALITY CERTIFICATION CENTRE**  
**CERTIFICATE OF CONFORMITY**

**Certificate No.: CE160304005131-A1**

***Product***

AC contactor

***Applicant***

Zhejiang Tengen Electric Co.,Ltd.

Sulv Industrial Area, Liushi Town, Yueqing City, Zhejiang  
Province, P.R.China

***Type/Model***

TGC1-80,TGC1-80N,TGC1-95,TGC1-95N,TGCG-80,TGC  
G-80N,TGCG-95,TGCG-95N,TGCJH-80,TGCJH-  
80N,TGCJH-95,TGCJH-95N

***Technical data***

See the Appendix

This is to certify that, on the basis of the tests undertaken as per Report No.  
CE-045-1C172143, the submitted sample(s) of the above item complies with:

**EN 60947-4-1:2010**

and fulfills testing requirements of the European Directive:

**2014/35/EU**

**Valid from:** Jul.18,2019

**Valid until:** Jul.18,2022

**President:**

Lu Mei



**CHINA QUALITY CERTIFICATION CENTRE**

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

<http://www.cqc.com.cn>



CHINA QUALITY CERTIFICATION CENTRE  
CERTIFICATE OF CONFORMITY

Appendix

Page 1 of 1

Certificate No.: CE160304005131-A1

TGC1-80,TGC1-80N,TGC1-95,TGC1-95N,TGCG-80,TGCG-80N,TGCG-95,TGCG-95N,TGCJH-80,TGCJH-80N,TGCJH-95,TGCJH-95N;

Ith:110A;

Ui:690V;

Uimp:8kV;

Us:50Hz,AC24V,AC36V,AC48V,AC110V,AC220V,AC380V,AC400V,AC415V;

50/60Hz,AC24V,AC36V,AC48V,AC110V,AC220V,AC380V,AC400V,AC415V;3P;

TGC1-80,TGC1-80N,TGCG-80,TGCG-80N,TGCJH-80,TGCJH-80N

AC-3: Ue:AC220V/230V,AC380V/400V;Ie:80A; Ue:AC660V/690V;Ie:49A;

AC-4:Ue:AC220V/230V,AC380V/400V;Ie:37A;Ue:AC660V/690V;Ie:17,3A;

TGC1-95,TGC1-95N,TGCG-95,TGCG-95N,TJHCJH-95,TJHCJH-95N

AC-3:Ue:AC220V/230V,AC380V/400V;Ie:95A;Ue:AC660V/690V;Ie:49A;

AC-4:Ue:AC220V/230V,AC380V/400V;Ie: 44A;Ue:AC660V/690V;Ie:21,3A;

Auxiliary switch:AC-15 Ue/Ie:380V/0,95A;DC-13 Ue/Ie:220V/0,15A;Ui:690V;Ith:10A;Uimp:6kV

President:

Lu Mei



CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

<http://www.cqc.com.cn>